

**AUTHORIZATION TO DISCHARGE UNDER THE
NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM**

In compliance with the provisions of the Federal Clean Water Act as amended, (33 U.S.C. §§1251 et seq.; the "CWA"), and the Massachusetts Clean Waters Act, as amended, (M.G.L. Chap. 21, §§26-53),

**Town of Hull
Permanent Sewer Commission**

is authorized to discharge from the facility located at

**Hull Water Pollution Control Facility
1111 Nantasket Avenue
Hull, MA 02045**

to receiving water named

Massachusetts Bay - Atlantic Ocean (Boston Harbor Watershed - 70)

in accordance with effluent limitations, monitoring requirements and other conditions set forth herein.

This permit shall become effective 60 days after signature.

This permit and the authorization to discharge expire at midnight, four (4) years from the effective date.

This permit supersedes the permit issued on November 18, 1996.

This permit consists of 10 pages in Part I including effluent limitations, monitoring requirements, Attachment A, Marine Acute Toxicity Test Procedure & Protocol, Attachment B, Sludge Guidance, and 35 pages in Part II including General Conditions and Definitions.

Signed this 6th day of May, 2002

/signature on file/

Linda M. Murphy, Director
Office of Ecosystem Protection
Environmental Protection Agency
Boston, MA

Director
Division of Watershed Management
Department of Environmental Protection
Commonwealth of Massachusetts
Boston, MA

PART I

A.1. During the period beginning the effective date and lasting through expiration, the permittee is authorized to discharge from outfall serial number **001**, treated effluent to Massachusetts Bay/Atlantic Ocean. Such discharges shall be limited and monitored as specified below.

<u>EFFLUENT CHARACTERISTIC</u>			<u>EFFLUENT LIMITS</u>		<u>MONITORING REQUIREMENTS</u>		
PARAMETER	<u>AVERAGE MONTHLY</u>	<u>AVERAGE WEEKLY</u>	<u>AVERAGE MONTHLY</u>	<u>AVERAGE WEEKLY</u>	<u>MAXIMUM DAILY</u>	<u>MEASUREMENT FREQUENCY</u>	<u>SAMPLE³ TYPE</u>
FLOW	***	***	3.07 MGD ^{1,2}	***	Report MGD	CONTINUOUS	RECORDER
BOD ₅ ³	768 lbs/Day 349 kgs/Day	1152 lbs/Day 523 kgs/Day	30 mg/l	45 mg/l	50 mg/l	WEEKLY	24-HOUR COMPOSITE ⁴
TSS ³	768 lbs/Day 349 kgs/Day	1152 lbs/Day 523 kgs/Day	30 mg/l	45 mg/l	50 mg/l	WEEKLY	24-HOUR COMPOSITE ⁴
pH RANGE ¹	6.5 - 8.5 SU SEE PERMIT PAGE 4 PARAGRAPH I.A.1.b.					WEEKLY	GRAB
TOTAL CHLORINE RESIDUAL ¹	***	***	0.705 mg/l	***	1 mg/l	3/DAY	GRAB
FECAL COLIFORM ^{1,6}	***	***	88/100 ml	***	260/100 ml	1/WEEK	GRAB
WHOLE EFFLUENT TOXICITY ^{7,8}	Acute LC ₅₀ ≥ 100%					4/YEAR	24-HOUR COMPOSITE

Footnotes:

1. Required for State Certification.
2. For flow, report maximum and minimum daily rates and total flow for each operating date. This is an annual average limit, which shall be reported as a rolling average. The first value will be calculated using the monthly average flow for the first full month ending after the effective date of the permit and the eleven previous monthly average flows. Each subsequent month's DMR will report the annual average flow for the previous 12 months.
3. All required effluent samples shall be collected at the discharge from the chlorine contact tank. Any change in sampling location must be reviewed and approved in writing by EPA and MADEP. All samples shall be tested using the analytical methods found in 40 CFR §136, or alternative methods approved by EPA in accordance with the procedures in 40 CFR §136. All samples shall be 24 hour composites unless specified as a grab sample in 40 CFR §136.
4. Sampling required for influent and effluent.
5. A 24-hour composite sample will consist of at least twenty four (24) grab samples taken during one working day (e.g. 0700 Monday to 0700 Tuesday).
6. This is also a State certification requirement. Fecal coliform bacteria discharges shall not exceed a fecal coliform median or a geometric mean MPN of 88 per 100 ml, nor shall more than 10% of the samples exceed a MPN of 260 per 100 ml. This monitoring shall be conducted concurrently with the TRC sampling.
7. The permittee shall perform modified acute toxicity tests four times per year. The tests must be performed in accordance with test procedures and protocols specified in **Attachment A** of this permit.

Test Dates Second Week in	Submit Results By:	Test Species	Acute Limit LC ₅₀
February May August November	March 30 th June 30 th September 30 th December 30 th	Menidia Beryllina	≥ 100%

After submitting four consecutive sets of WET test results, all of which demonstrate compliance with the WET permit limits, the permittee may request a reduction in the frequency of required WET testing. The permittee is required to continue testing at the frequency specified in the permit until notice is received by certified mail from the EPA that the WET testing requirement has been changed.

8. The LC_{50} is the concentration of effluent which causes mortality to 50% of the test organisms. Therefore, a 100% limit means that a sample of 100% effluent (no dilution) shall cause no more than a 50% mortality rate.

Part I.A.1. (Continued)

- a. The discharge shall not cause a violation of the water quality standards of the receiving waters.
 - b. The pH of the effluent shall not be less than 6.5 nor greater than 8.5 at any time, unless these values are exceeded as a result of an approved treatment process.
 - c. The discharge shall not cause objectionable discoloration of the receiving waters.
 - d. The effluent shall contain neither a visible oil sheen, foam, nor floating solids at any time.
 - e. The permittee's treatment facility shall maintain a minimum of 85 percent removal of both total suspended solids and biochemical oxygen demand. The percent removal shall be based on monthly average values.
 - f. When the effluent discharged for a period of 90 consecutive days exceeds 80 percent of the designed flow, the permittee shall submit to the permitting authorities a projection of loadings up to the time when the design capacity of the treatment facility will be reached, and a program for maintaining satisfactory treatment levels consistent with approved water quality management plans.
 - g. The permittee shall minimize the use of chlorine while maintaining adequate bacterial control.
 - h. The results of sampling for any parameter above its required frequency must also be reported.
2. All POTWs must provide adequate notice to the Director of the following:
- a. Any new introduction of pollutants into that POTW from an indirect discharger in a primary industry category discharging process water; and
 - b. Any substantial change in the volume or character of pollutants being introduced into that POTW by a source introducing pollutants into the POTW at the time of issuance of the permit.
 - c. For purposes of this paragraph, adequate notice shall include information on:
 - (1) the quantity and quality of effluent introduced into the POTW; and
 - (2) any anticipated impact of the change on the quantity or quality of effluent to be discharged from the POTW.

3. Prohibitions Concerning Interference and Pass Through:

- a. Pollutants introduced into POTW's by a non-domestic source (user) shall not pass through the POTW or interfere with the operation or performance of the works.
- b. If, within 30 days after notice of an interference or pass through violation has been sent by EPA to the POTW, and to persons or groups who have requested such notice, the POTW fails to commence appropriate enforcement action to correct the violation, EPA may take appropriate enforcement action.

4. Toxics Control

- a. The permittee shall not discharge any pollutant or combination of pollutants in toxic amounts.
- b. Any toxic components of the effluent shall not result in any demonstrable harm to aquatic life or violate any state or federal water quality standard which has been or may be promulgated. Upon promulgation of any such standard, this permit may be revised or amended in accordance with such standards.

5. Numerical Effluent Limitations for Toxicants

EPA or DEP may use the results of the toxicity tests and chemical analyses conducted pursuant to this permit, as well as national water quality criteria developed pursuant to Section 304(a)(1) of the Clean Water Act (CWA), state water quality criteria, and any other appropriate information or data, to develop numerical effluent limitations for any pollutants, including but not limited to those pollutants listed in Appendix D of 40 CFR Part 122.

C. UNAUTHORIZED DISCHARGES

The permittee is authorized to discharge only in accordance with the terms and conditions of this permit and only from outfalls listed in Part I A.1. of this permit. Discharges of wastewater from any other point sources, including sanitary sewer overflows (SSOs) are not authorized by this permit and shall be reported in accordance with Section D.1.e. (1) of the General Requirements of this permit (Twenty-four hour reporting).

D. OPERATION AND MAINTENANCE OF THE SEWER SYSTEM

Operation and maintenance of the sewer system shall be in compliance with the General Requirements of Part II and the following terms and conditions:

1. Maintenance Staff

The permittee shall provide an adequate staff to carry out the operation, maintenance, repair, and testing functions required to ensure compliance with the terms and conditions of this permit.

2. Preventative Maintenance Program

The permittee shall maintain an ongoing preventative maintenance program to prevent overflows and bypasses caused by malfunctions or failures of the sewer system infrastructure. The program shall include an inspection program designed to identify all potential and actual unauthorized discharges.

3. Infiltration/Inflow Control Plan:

The permittee shall develop and implement a plan to control infiltration and inflow (I/I) to the separate sewer system. The plan shall be submitted to EPA and MA DEP within six months of the effective date of this permit (see page 1 of this permit for the effective date) and shall describe the permittee's program for preventing infiltration/inflow related effluent limit violations, and all unauthorized discharges of wastewater, including overflows and by-passes due to excessive infiltration/inflow.

The plan shall include:

- An ongoing program to identify and remove sources of infiltration and inflow. The program shall include the necessary funding level and the source(s) of funding.
- An inflow identification and control program that focuses on the disconnection and redirection of illegal sump pumps and roof down spouts. Priority should be given to removal of public and private inflow sources that are upstream from, and potentially contribute to, known areas of sewer system backups and/or overflows
- Identification and prioritization of areas that will provide increased aquifer recharge as the result of reduction/elimination of infiltration and inflow to the system.
- An educational public outreach program for all aspects of I/I control, particularly private inflow.

Reporting Requirements:

A summary report of all actions taken to minimize I/I during the previous calendar year shall be submitted to EPA and the MA DEP annually, by the anniversary date of the effective date of this permit. The summary report shall, at a minimum, include:

- A map and a description of inspection and maintenance activities conducted and corrective actions taken during the previous year.
- Expenditures for any infiltration/inflow related maintenance activities and corrective actions taken during the previous year
- A map with areas identified for I/I-related investigation/action in the coming year.
- A calculation of the annual average I/I, the maximum month I/I for the reporting year.

- A report of any infiltration/inflow related corrective actions taken as a result of unauthorized discharges reported pursuant to 314 CMR 3.19(20) and reported pursuant to the Unauthorized Discharges section of this permit.

4. Alternate Power Source

In order to maintain compliance with the terms and conditions of this permit, the permittee shall continue to provide an alternative power source with which to sufficiently operate its treatment works (as defined at 40 CFR §122.2).

5. Chlorination System Report

Within 12 months of the effective date of the permit, the permittee will submit a report documenting the effectiveness of the chlorination system. The report will specifically address how flow variability and chlorine demand variability affect compliance with the TRC and fecal coliform limits at all times. Sampling data shall be provided to support conclusions on how hourly and daily flow and chlorine demand variability affects permit compliance. The report will include a description of the chlorination system and the methods for dosage control. The report will identify all changes necessary to ensure compliance with the TRC and fecal coliform limits at all times, including equipment modifications and upgrades, operational procedures (including calibration procedures and alarm/response procedures), and sampling protocols. The report will include a schedule for implementing all of the necessary changes. An annual report shall be submitted on February 19 of each year to the addresses in the Monitoring and Reporting Section below, summarizing all exceedances of the TRC and fecal coliform effluent limits during the previous year, the estimated or measured fecal coliform and chlorine discharge levels during the exceedance, and measures taken to fix the problem and to prevent future occurrences.

6. Dye Study

Within 18 months of the effective date of the permit, the permittee shall conduct a single dye study. Timing of the study will be determined through consultation with the Massachusetts Division of Marine Fisheries (MA DMF).

The area of concern is defined as extending from the mean low water line seaward for one nautical mile at the southeasterly extent of Nantasket Beach, continuing northerly through Nantasket Roads, past the plant outfall and westerly to include the contiguous waters around Peddocks Island.

The applicant shall work with the MA DMF to develop a scope of work for the dye study to assure it addresses the concerns of MA DMF. MA DMF has agreed to work with the permittee through this process.

The permittee shall submit a scope of work for the dye study to EPA, MA DEP and MA DMF for review thirty (30) days prior to start of work.

The dye shall be introduced into the plant effluent at a constant rate over one complete high and low tide cycle. Field monitoring should include meteorological information including but not limited to wind speed, wind direction, air and surface water temperature, and precipitation, if

any. Field monitoring should include the determination of maximum spatial extent of the dye, the time of travel, and dispersion and dilution characteristics, during and after the dye is introduced into the effluent. Continuous monitoring of the time of travel and dispersion shall be implemented during the tidal cycle.

Results of the study shall be submitted to EPA, MA DEP and MA DMF within 45 days of completion of the study.

E. SLUDGE CONDITIONS

1. The permittee shall comply with all existing federal and state laws and regulations that apply to sewage sludge use and disposal practices and with the CWA Section 405(d) technical standards.
2. The permittee shall comply with the more stringent of either the state or federal (40 CFR part 503), requirements.
3. The requirements and technical standards of 40 CFR part 503 apply to facilities which perform one or more of the following use or disposal practices.
 - a. Land application - the use of sewage sludge to condition or fertilize the soil
 - b. Surface disposal - the placement of sewage sludge in a sludge only landfill
 - c. Sewage sludge incineration in a sludge only incinerator
4. The 40 CFR part 503 conditions do not apply to facilities which place sludge within a municipal solid waste landfill. These conditions also do not apply to facilities which do not dispose of sewage sludge during the life of the permit but rather treat the sludge (lagoons- reed beds), or are otherwise excluded under 40 CFR 503.6.
5. The permittee shall use and comply with the attached compliance guidance document to determine appropriate conditions. Appropriate conditions contain the following elements.
 - General requirements
 - Pollutant limitations
 - Operational Standards (pathogen reduction requirements and vector attraction reduction requirements)
 - Management practices
 - Record keeping
 - Monitoring
 - Reporting

Depending upon the quality of material produced by a facility, all conditions may not apply to the facility.

6. The permittee shall monitor the pollutant concentrations, pathogen reduction and vector attraction reduction at the following frequency. This frequency is based upon the volume of sewage sludge generated at the facility in dry metric tons per year

less than 290	1/ year
290 to less than 1500	1 /quarter
1500 to less than 15000	6 /year
15000 +	1 /month

7. The permittee shall sample the sewage sludge using the procedures detailed in 40 CFR 503.8.
8. The permittee shall submit an annual report containing the information specified in the guidance on February 19. Reports shall be submitted to the address contained in the reporting section of the permit. Sludge monitoring is not required by the permittee when the permittee is not responsible for the ultimate sludge disposal. The permittee must be assured that any third party contractor is in compliance with appropriate regulatory requirements. In such case, the permittee is required only to submit an annual report on February 19 containing the following information:
 - Name and address of contractor responsible for sludge disposal
 - Quantity of sludge in dry metric tons removed from the facility by the sludge contractor

F. MONITORING AND REPORTING

1. Reporting

Monitoring results obtained during each calendar month shall be summarized and reported on Discharge Monitoring Report Form(s) postmarked no later than the 15th day of the following month.

Signed and dated originals of these, and all other reports required herein, shall be submitted to the Director and the State at the following addresses:

Environmental Protection Agency
Water Technical Unit (SEW)
P.O. Box 8127
Boston, Massachusetts 02114

The State Agency is:

Massachusetts Department of Environmental Protection
Northeast Regional Office - BRP
205A Lowell Street
Wilmington, MA 01887

Signed and dated Discharge Monitoring Report Forms and toxicity test reports required by this permit shall also be submitted to the State at:

Massachusetts Department of Environmental Protection
Division of Watershed Management
Surface Water Discharge Permit Program
627 Main Street, 2nd Floor
Worcester, Massachusetts 01608

Massachusetts Division of Marine Fisheries
251 Causeway Street, Suite 400
Boston, Massachusetts 02114

G. STATE PERMIT CONDITIONS

This Discharge Permit is issued jointly by the U. S. Environmental Protection Agency (EPA) and the Massachusetts Department of Environmental Protection (DEP) under Federal and State law, respectively. As such, all the terms and conditions of this permit are hereby incorporated into and constitute a discharge permit issued by the Commissioner of the MA DEP pursuant to M.G.L. Chap.21, §43.

Each Agency shall have the independent right to enforce the terms and conditions of this Permit. Any modification, suspension or revocation of this Permit shall be effective only with respect to the Agency taking such action, and shall not affect the validity or status of this Permit as issued by the other Agency, unless and until each Agency has concurred in writing with such modification, suspension or revocation. In the event any portion of this Permit is declared, invalid, illegal or otherwise issued in violation of State law such permit shall remain in full force and effect under Federal law as an NPDES Permit issued by the U.S. Environmental Protection Agency. In the event this Permit is declared invalid, illegal or otherwise issued in violation of Federal law, this Permit shall remain in full force and effect under State law as a Permit issued by the Commonwealth of Massachusetts.